

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by DR. SAURABH SIL, ACMOH (S), COB, and Manoranjan Guha, H-1, ACMOH (S), COB, (Name of Officers with designation) from ACMOH Sadar office

(Name of Department/ Office) inspected the TECHNO INDIA GROUP PUBLIC SCHOOL Matikata, Madhupur More, Cooch Beha, 736165 (Name & Address of the school) on 19/06/2023 (date of inspection) and found that the

Techno India Group Public School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year Memo No. 162/JACMOH(S)/COB/ Date 19/06/23 19/06/2023

Manoranjan Guha H-1 ACMOH (S) office COB

Signature with Seal: Asst. C.M.O. (Sadar) Cooch Behar Name DR. SAURABH SIL Designation ACMOH, Sadar, Cooch Behar

Name & Address of the Office / Department:

ACMOH, Sadar, Office Cooch Behar H & Fw Dept.

To TECHNO INDIA GROUP PUBLIC SCHOOL, MATIKATA, MADHUPUR MORE, COB-736165 (Name & Address of the Institution)

Signature of Manager Techno India Group Public School Cooch Behar, West Bengal

Signature of Principal Techno India Group Public School Cooch Behar

GOVT OF WEST BENGAL

PUBLIC HEALTH ENGINEERING DIRECTORATE
OFFICE OF THE EXECUTIVE ENGINEER, COOCH BEHAR DIVISION
DEBIBARI, LICHUTALA, COOCH BEHAR

COOCH BEHAR DISTRICT LABORATORY, COOCH BEHAR

TEST REPORT OF WATER QUALITY (Chemical, Physical & Bacteriological), ID : 789/06/23/SL No. 27, 28, 29, 30 and 31

Date of Collection : 13.06.2023

Date of Test : 13.06.2023 to 14.06.2023

Sl. No.	Location Description	Type of Water Source	Chemical and Physical Parameter							Parameter		Remarks	
			Iron (mg/lt)	Total Hardness (mg/lt)	Mn (mg/lt)	pH	Calcium (mg/lt)	Magnesium (mg/lt)	TDS (mg/lt)	Turbidity (NTU)	Total Coliform (MFL)		Faecal Coliform (MFL)
TECHNO INDIA GROUP PUBLIC SCHOOL, MATIKATA, MADHUPUR MORE, COOCH BEHAR, PIN - 736 165													
1	Computer Lab slide (Filter Water)	Ground Water	0.30	220.35	0.01	7.29	58.80	19.41	237.0	0.60	0	0	NORMAL
2	Head Mistress Room (Filter Water)	Ground Water	0.32	216.32	0.01	7.22	54.18	19.41	237.0	0.78	0	0	NORMAL
3	Staff Room - 2 (Filter Water)	Ground Water	0.37	212.76	0.01	7.40	54.18	18.44	227.0	0.76	0	0	NORMAL
4	Biology Lab 1st Floor (Filter Water)	Ground Water	0.43	208.22	0.01	7.38	53.37	17.95	221.0	0.81	0	0	NORMAL
5	Class - IX C 2nd Floor (Filter Water)	Ground Water	0.58	210.24	0.02	7.25	53.37	18.44	225.0	0.92	0	0	NORMAL
Desirable limit for drinking water as per IS 10500 : 2012			1	200	0.1	6.5-8.5	75	30	500	1	0	0	
Permissible limit for drinking water as per IS 10500 : 2012 & D.O.WQ - 11021/7/2016-WQ			1	600	0.3	6.5-8.5	200	100	2000	5	0	0	

Signature of Chemist

Chemist
Cooch Behar District
Water Testing Laboratory, PHE Div
Cooch Behar Division, PHE Div

Signature of Bacteriologist

Bacteriologist
Cooch Behar District
Water Testing Laboratory, PHE Div
Cooch Behar Division, PHE Div

Assistant Engineer
RWS, Cooch Behar Sub-Division
PHE Div

Assistant Engineer
RWS Cooch Behar Sub-Divn.
PHE Div.
GOVT. of West Bengal

[Signature]

Manager
Techno India Group Public School,
Cooch Behar, West Bengal

Principal

Techno India Group Public School
Cooch Behar

[Signature]