



GOVT OF WEST BENGAL
PUBLIC HEALTH ENGINEERING DIRECTORATE
OFFICE OF THE EXECUTIVE ENGINEER, COOCH BEHAR DIVISION
DEBIBARI, LICHUTALA, COOCH BEHAR

Memo No. : 531/CD

Date : Cooch Behar 21/06/23

To
The Principal,
Techno India Group Public School,
Matikata, Madhupur More,
Cooch Behar,
Pin - 736 165

Sub : Chemical, Physical and Bacteriological analysis report of 05 (Five) nos.
water samples mentioned in the test results

With reference to the above enclosed herewith please find the chemical, physical and bacteriological analysis report for 05 (Five) nos. of water samples of the said location tested. All the test results are normal. Water samples test results are enclosed.

Encl : As stated


21/6/2023
Executive Engineer
Cooch Behar Division
PHE Dte
Executive Engineer
Cooch Behar Division
P.H.E. Dte., Govt. of W.B.


Memo No. : /CD

Date : Cooch Behar

Copy forwarded to :-

- 1) The Assistant Engineer, RWS, Cooch Behar Sub Division, PHE Dte
- 2) Lab Copy
- 3) Office Copy

Sd
Executive Engineer
Cooch Behar Division
PHE Dte


Principal
Techno India Group Public School
Cooch Behar
26/2/2026

GOVT OF WEST BENGAL
PUBLIC HEALTH ENGINEERING DIRECTORATE
OFFICE OF THE EXECUTIVE ENGINEER, COOCH BEHAR DIVISION
DEBIBARI, LICHUTALA, COOCH BEHAR
COOCH BEHAR DISTRICT LABORATORY, COOCH BEHAR

TEST REPORT OF WATER QUALITY (Chemical, Physical & Bacteriological), ID : 749/06/23/SL No. 27, 28, 29, 30 and 31

Date of Collection : 13.06.2023

Date of Test : 13.06.2023 to 14.06.2023

Sl. No.	Location Description	Type of Water Source	Chemical and Physical Parameter										Remarks
			Iron (mg/lit)	Total Hardness (mg/lit)	Mn (mg/lit)	pH	Calcium (mg/lit)	Magnesium (mg/lit)	TDS (mg/lit)	Turbidity (NTU)	Total Coliform (MFT)	Faecal Coliform (MFT)	
TECHNO INDIA GROUP PUBLIC SCHOOL, MATIKATA, MADHUPUR MORE, COOCH BEHAR, PIN - 736 165													
1	Computer Lab Side (Filter Water)	Ground Water	0.30	220.35	0.01	7.29	58.80	19.41	237.0	0.60	0	0	NORMAL
2	Head Mistress Room (Filter Water)	Ground Water	0.32	216.32	0.01	7.22	54.18	19.41	232.0	0.78	0	0	NORMAL
3	Staff Room - 2 (Filter Water)	Ground Water	0.37	212.26	0.01	7.40	54.18	18.44	227.0	0.76	0	0	NORMAL
4	Biology Lab 1st Floor (Filter Water)	Ground Water	0.43	208.22	0.01	7.38	53.37	17.95	221.0	0.81	0	0	NORMAL
5	Class - IX C 2nd Floor (Filter Water)	Ground Water	0.58	210.24	0.02	7.25	53.37	18.44	225.0	0.92	0	0	NORMAL
Desirable limit for drinking water as per IS 10500 : 2012			1	200	0.1	6.5-8.5	75	30	500	1	0	0	
Permissible limit for drinking water as per IS 10500 : 2012 & D.O.WQ - 11021/7/2016-WQ			1	600	0.3	6.5-8.5	200	100	2000	5	0	0	

[Signature]
Signature of Chemist

Chemist
 Cooch Behar District
 Water Testing Laboratory
 Cooch Behar Division, PHE, Dte

[Signature]
Signature of Bacteriologist

Bacteriologist
 Cooch Behar District
 Water Testing Laboratory
 Cooch Behar Division, PHE, Dte

[Signature]
Assistant Engineer
 RWS, Cooch Behar Sub - Division
 PHE Dte

Assistant Engineer
 RWS Cooch Behar Sub-Divn.
 P.H.E. Dte.
 Govt. of West Bengal

[Signature]
Principal
 Techno India Group Public School
 Cooch Behar
 26/2/2023